

FAR 3847 C1 Issue 3

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor:

WonDoor Corporation
1865 South 3480 West
Salt Lake City
Utah 84104
USA

Reference BRANZ Reports: FAR 3847 Issue 3

Referenced Standard: AS 1530.4:2014

Specimen Name: Won-Door FireGuard and Won-Door Access FireGuard

Specimen Description: Accordion sliding fire door, single or bi-parting

Orientation: Exposure from either side

The assessed results were as follows:

It is considered that based on the UL test report File R6799-2 Project 97NK30045 and File R6799-6 Project No. 83NK21332, if the single or bi-parting sliding doorset had been tested in accordance with AS 1530.4:2014 for an un-insulated specimen it would have achieved at least 120 minutes Integrity.

Issued by

A handwritten signature in blue ink, appearing to read "A. Babb".

A. Babb
Fire Testing Engineer
BRANZ

Reviewed by

A handwritten signature in blue ink, appearing to read "P. Chapman".

P. Chapman
Senior Fire Testing Engineer
IANZ Approved Signatory

Regulatory authorities are advised to examine Technical Opinion report FAR 3847 Issue 3 before approving any product.

Issue Date

17 November 2022

Expiry Date

17 November 2027